

**Drinking Water Quality and Compliance- Annual Notice to Consumers
RM of Moosomin No. 121 ---Division 7**

Introduction

The Water Security Agency and the Ministry of Environment requires that at least once each year waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Minister's Order or Permit to Operate a waterworks. The following is a summary of the RM of Moosomin No. 121-Division 7 water quality and sample submission compliance record for the 01 January 2018 to December 31, 2018 time period. This report was completed on June 26, 2019. Readers should refer to Water Security Agency's "Municipal Drinking Water Quality Monitoring Guidelines, June 2015, EPB 502" for more information on minimum sample submission requirements and the meaning of type of sample. Permit requirements for a specific waterworks may require more sampling than outlined in the department's monitoring guidelines. If consumers need more information on the nature and significance of specific water tests, for example, "what is the significance of Selenium in a water supply", more detailed information is available from: http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index_e.html

Water Quality Standards

Bacteriological Quality

Parameter/Location	Limit	Regular Samples Required	Regular Samples Submitted	# of Positive Regular Submitted (%)
Total Coliform and E.coli	0 Organisms/100 mL	24	24	0%
Background Bacteria	Less than 200/100 mL			

Water Disinfection –

Chlorine Residual in Distribution System for Test Results Submitted with Bacteriological Samples

Parameter	Minimum Limit	Total Chlorine Residual Range	Free Chlorine Residual Range	# Tests Required	# Tests Submitted	# Adequate Chlorine (%)
Chlorine Residual	0.1 mg/L free OR 0.5 mg/L total	0.64– 2.01	0.43 – 1.69	24	24	100%

Water Disinfection - Free Chlorine Residual for Water Entering Distribution System from Waterworks Records-From Water Treatment Plant Records

Parameter	Limit (mg/L)	Test Level Range	# Tests Performed	# Tests Not Meeting Requirements
Free Chlorine Residual	at least 0.1	0.01 – 1.78	365	3

A minimum of 0.1 milligrams per litre (mg/L) free chlorine residual is required for water entering the distribution system. Tests are normally performed on a daily basis by the waterworks operator and are to be recorded in operation records. This data includes the number of free chlorine residual tests performed, the overall range of free chlorine residual (highest and lowest recorded values) and the number of tests and percentage of results not meeting the minimum requirement of 0.1 mg/L free chlorine residual.

Turbidity – From Water Treatment Plant Records

Parameter	Limit (NTU)	Test Level Range	# Tests Not Meeting Requirements	Maximum Turbidity (NTU)	# Tests Required	# Tests Performed	Perfor
Turbidity	1	0.11 – 1.40	8	1.40	365	365	

Chemical – Health Category

All waterworks serving less than 5000 persons are required to submit water samples for SE's Chemical Health category once every 2 years. The Chemical Health category includes analysis for arsenic, barium, boron, cadmium, chromium, fluoride, lead, nitrate, selenium and uranium.

The next sample for Chemical Health analysis will be submitted in 2020.
The next sample for General Chemical analysis will be submitted in 2020.

More information on water quality and sample submission performance may be obtained from:

RM of Moosomin No. 121
Box 1109
Moosomin, SK S0G 3N0
Telephone Number 306-435-3113 Ext. 1

Parameter	Limit MAC(ug/L)	Limit IMAC (mg/L)	Sample Result(s)	# Samples Exceeding Limit	
Aluminum			<6.96 ug/l		
Arsenic	< 10		0.6 ug/L	_____	* Results expressed
Barium	< 1000		2.2 ug/L	_____	as average values
Boron		< 5.0	0.2 mg/L	_____	for communities or
Cadmium	< 5.		<0.15 ug/L	_____	waterworks that
Chromium	< 50		<0.30 ug/L	_____	fluoridate drinking
Copper	< 1000		<8.29 ug/l		
Fluoride (avg*)	1.5		-	_____	water supplies or
Lead	< 10		< 0.10 ug/L	_____	those with elevated
Nitrate (avg.*)	45.0		-	_____	concentrations of
Selenium	< 10		<1.13 ug/L	_____	fluoride or nitrates.
Uranium	< 20		0.50	_____	
Zinc	< 5000		<4.00		

Chemical – Trihalomethanes (THMs) N/A

Parameter	THMs Limit (mg/L)	Sample Result (average)	# Samples Required	# Samples Submitted
Trihalomethanes	0.1	_____	4 (1 every 3 months)	_____

Note: Only water supplies derived from surface water or groundwater under the influence of surface water are required to monitor for THMs. Waterworks using groundwater sources beyond the influence of surface water do not need to report THMs since sampling/analysis will not likely have been performed.

General Chemical

Parameter	Aesthetic Objectives * (mg/L)	Sample Results (average)	# Samples Required	# Samples Submitted
Alkalinity	<500	427 mg/L	1	1
Bicarbonate	No Objective	521 mg/L	1	1
Calcium	No Objective	176 mg/L	1	1
Carbonate	No Objective	0-0	1	1
Chloride	250	21.8 mg/L	1	1
Conductivity	No Objective	1371 uS/cm	1	1
Fluoride Dis.	1.5	0.16 mg/L	1	1
Hardness	800	682 mg/L	1	1
Iron	0.3	0.1 mg/L	1	1
Manganese	0.05	0.01 mg/L	1	1
Magnesium	200	59 mg/L	1	1
Nitrate	45	0.5 mg/L	1	1
PH	No Objective	7.4 pH units	1	1
Potassium	No Objective	8 mg/L	1	1
Sodium	300	74 mg/L	1	1
Sulphate	500	356.9 mg/L	1	1
Total dissolved Solids	1500	1217 mg/L	1	1

All waterworks serving less than 5000 persons are required to submit water samples for SE's General Chemical category once every two years if a ground water source and once per three months every second year if a surface water or blended surface/groundwater source. The General Chemical category includes analysis for alkalinity, bicarbonate, calcium, carbonate, chloride, conductivity, hardness (as CaCO₃), magnesium, sodium, sulphate and total dissolved solids.

The last sample for General Chemical analysis was required in 2018 and submitted on October 9, 2018. Sample results indicated that there were no exceedences of the provincial aesthetic objectives for the General Chemical category

*Objectives apply to certain characteristics of or substances found in water for human consumptive or hygienic use. The presence of these substances will affect the acceptance of water by consumers and/or interfere with the practice of supplying good quality water. Compliance with drinking water aesthetic objectives is not mandatory as these objectives are in the range where they do not constitute a health hazards. The aesthetic objectives for several parameters (including hardness as CaCO₃, magnesium, sodium and total dissolved solids) consider regional differences in drinking water sources and quality.

More information on water quality and sample submission performance may be obtained from:

RM of Moosomin
 Box 1109, Moosomin
 Saskatchewan S0G 3N0
 Telephone Number 306-435-3113 Ext. 1