

**Drinking Water Quality and Compliance- Annual Notice to Consumers**  
**RM of Moosomin No. 121 ---Division 7**  
**(Special Service Area of Welwyn)**

**Introduction**

The Water Security Agency and the Ministry of Environment requires that at least once each year waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Minister's Order or Permit to Operate a waterworks. The following is a summary of the RM of Moosomin No. 121-Division 7 (Special Service area of Welwyn) water quality and sample submission compliance record for the 01 January 2020 to December 31, 2020 time period. This report was completed on March 15, 2021. Readers should refer to Water Security Agency's "Municipal Drinking Water Quality Monitoring Guidelines, June 2015, EPB 502" for more information on minimum sample submission requirements and the meaning of type of sample. Permit requirements for a specific waterworks may require more sampling than outlined in the department's monitoring guidelines. If consumers need more information on the nature and significance of specific water tests, for example, "what is the significance of Selenium in a water supply", more detailed information is available from: [http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index\\_e.html](http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index_e.html)

**Water Quality Standards**

**Bacteriological Quality**

Parameter/Location	Limit	Regular Samples Required	Regular Samples Submitted	# of Positive Regular Submitted (%)
Total Coliform and E.coli	0 Organisms/100 mL	24	24	0%
Background Bacteria	Less than 200/100 mL			

**Water Disinfection –**

**Chlorine Residual in Distribution System for Test Results Submitted with Bacteriological Samples**

Parameter	Minimum Limit	Total Chlorine Residual Range	Free Chlorine Residual Range	# Tests Required	# Tests Submitted	# Adequate Chlorine (%)
Chlorine Residual	0.1 mg/L free OR 0.5 mg/L total	0.60– 2.19	0.40 – 1.81	24	21	100%

**Water Disinfection - Free Chlorine Residual for Water Entering Distribution System from Waterworks Records-From Water Treatment Plant Records**

Parameter	Limit (mg/L)	Test Level Range	# Tests Performed	# Tests Not Meeting Requirements
Free Chlorine Residual	at least 0.1	0.37 – 2.04	365	3

*A minimum of 0.1 milligrams per litre (mg/L) free chlorine residual is required for water entering the distribution system. Tests are normally performed on a daily basis by the waterworks operator and are to be recorded in operation records. This data includes the number of free chlorine residual tests performed, the overall range of free chlorine residual (highest and lowest recorded values) and the number of tests and percentage of results not meeting the minimum requirement of 0.1 mg/L free chlorine residual.*

**Turbidity – From Water Treatment Plant Records**

Parameter	Limit (NTU)	Test Level Range	# Tests Not Meeting Requirements	Maximum Turbidity (NTU)	# Tests Required	# Tests Performed
Turbidity	1	0.29 – 1.97	3	1.97	365	365

**Chemical – Health Category**

All waterworks serving less than 5000 persons are required to submit water samples for SE's Chemical Health category once every 2 years. The Chemical Health category includes analysis for arsenic, barium, boron, cadmium, chromium, fluoride, lead, nitrate, selenium and uranium.

The last sample for the General Chemical Health analysis was submitted on July 6, 2020. Same results indicated that the provincial drinking water quality standards were not exceeded.

The last sample for General Chemical analysis was required in 2020 and submitted on July 6, 2020. Sample results indicated that there were no exceedences of the provincial aesthetic objectives for the General Chemical category

The next sample for Chemical Health analysis will be submitted in 2022.  
 The next sample for General Chemical analysis will be submitted in 2022.

**More information on water quality and sample submission performance may be obtained from:**

RM of Moosomin No. 121  
 Box 1109  
 Moosomin, SK S0G 3N0  
 Telephone Number 306-435-3113 Ext. 1

Parameter	Limit MAC(ug/L)	Limit IMAC (mg/L)	Sample Result(s)	# Samples Exceeding Limit	
Aluminum			<6.96 ug/l		
Arsenic	< 10		0.6 ug/L	_____	* Results expressed as average values for communities or waterworks that fluoridate drinking water supplies or those with elevated concentrations of fluoride or nitrates.
Barium	< 1000		2.8 ug/L	_____	
Boron		< 5.0	0.2 mg/L	_____	
Cadmium	< 5.		<0.15 ug/L	_____	
Chromium	< 50		1.1 ug/L	_____	
Copper	< 1000		<8.29 ug/l	_____	
Fluoride (avg*)	1.5		-	_____	
Lead	< 10		0.10 ug/L	_____	
Nitrate (avg.*)	45.0		-	_____	
Selenium	< 10		<1.13 ug/L	_____	
Uranium	< 20		0.60	_____	
Zinc	< 5000		<4.00	_____	
Antimony			<0.16 ug/L		
Silver			<0.20 ug/L		

**Chemical – Trihalomethanes (THMs) N/A**

Parameter	THMs Limit (mg/L)	Sample Result (average)	# Samples Required	# Samples Submitted
Trihalomethanes	0.1	_____	4 (1 every 3 months)	_____

*Note: Only water supplies derived from surface water or groundwater under the influence of surface water are required to monitor for THMs. Waterworks using groundwater sources beyond the influence of surface water do not need to report THMs since sampling/analysis will not likely have been performed.*

**General Chemical**

Parameter	Aesthetic Objectives * (mg/L)	Sample Results (average)	# Samples Required	# Samples Submitted
Alkalinity	<500	430 mg/L	1	1
Bicarbonate	No Objective	525 mg/L	1	1
Calcium	No Objective	159 mg/L	1	1
Carbonate	No Objective	0-0	1	1
Chloride	250	20.4 mg/L	1	1
Conductivity	No Objective	1375 uS/cm	1	1
Fluoride Dis.	1.5	0.19 mg/L	1	1
Hardness	800	632 mg/L	1	1
Iron	0.3	< 0.1 mg/L	1	1
Manganese	0.05	0.02 mg/L	1	1
Magnesium	200	57 mg/L	1	1
Nitrate	45	0.8 mg/L	1	1
PH	No Objective	7.5 pH units	1	1
Potassium	No Objective	9 mg/L	1	1
Sodium	300	69 mg/L	1	1
Sulphate	500	351.2 mg/L	1	1
Total dissolved Solids	1500	1191 mg/L	1	1

All waterworks serving less than 5000 persons are required to submit water samples for SE's General Chemical category once every two years if a ground water source and once per three months every second year if a surface water or blended surface/groundwater source. The General Chemical category includes analysis for alkalinity, bicarbonate, calcium, carbonate, chloride, conductivity, hardness (as CaCO<sub>3</sub>), magnesium, sodium, sulphate and total dissolved solids.

\*Objectives apply to certain characteristics of or substances found in water for human consumptive or hygienic use. The presence of these substances will affect the acceptance of water by consumers and/or interfere with the practice of supplying good quality water. Compliance with drinking water aesthetic objectives is not mandatory as these objectives are in the range where they do not constitute a health hazards. The aesthetic objectives for several parameters (including hardness as CaCO<sub>3</sub>, magnesium, sodium and total dissolved solids) consider regional differences in drinking water sources and quality.

**More information on water quality and sample submission performance may be obtained from:**

RM of Moosomin  
Box 1109, Moosomin  
Saskatchewan S0G 3N0  
Telephone Number 306-435-3113 Ext. 1